



Certificate of Compliance

Certificate: 70206029

Master Contract: 177111

Project: 80055795

Date Issued: 2020-09-10

Issued To: Hermetic Pumpen GmbH
Gewerbestrasse 51
Gundelfingen, Baden-Württemberg, 79194
Germany

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: *Viorel Popovici*
Viorel Popovici P. Eng.



PRODUCTS

CLASS – 3851-01 - LIQUID PUMPS

CLASS – 3851-81 - LIQUID PUMPS Certified to US Standards

Commercial/industrial liquid pumps, centrifugal with canned motor, permanently cord connected without plug CAM, CNF and CN Series rated 240V, 480V to 600V max., 3ph, 60Hz, 21.3HP. Acceptance of pumps enclosure as Type 4.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 108-14 - Liquid pumps
UL 778 - Motor-Operated Water Pumps



Supplement to Certificate of Compliance

Certificate: 70206029

Master Contract: 177111

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80055795	2020-09-10	Update to 70206029 Report regarding the commercial/industrial liquid pumps, centrifugal with canned motor, permanently cord connected without plug CAM, CNF and CN Series rated 240V, 480V to 600V max., 3ph, 60Hz, 21.3HP. Acceptance of pumps enclosure as Type 4. Update to the requirements of UL 778 6th Edition.
70206029	2020-05-28	CSA Certification of commercial/industrial liquid pumps, centrifugal with canned motor, permanently cord connected without plug CAM and CNF Series rated 600V max., 3ph, 60Hz, 13HP max. and CN Series, rated 600V max., 3ph, 60Hz, 21.3 HP max. Acceptance of pumps enclosure as Type 1. To the requirements of CSA C22.2 No. 108-14. New Report. WMTC Initial Qualification Assessments. The new report supersedes the 1813625 Report. Cancel the FIR 177112-171120.